



aitex®  
research & innovation center

## FIRE BEHAVIOUR

### Applicant:

ROSCO IBERICA,S.A

Calle del Oro 76 pol ind Sur  
ES-28770 COLMENAR VIEJO  
Madrid

Is authorized to place the label "Curtains Fire Performance Classification" label according to the 2023AN2118.



### CLASSIFICATION OF FIRE BEHAVIOUR: CURTAINS

Nº: 23AN2118



The sample referenced as:

"MUSLIN ESCENICA"

### MATERIAL:

White fabric. Composition: 100% cotton, with a weight of 248 g/m².

Has been tested according to the standards EN 1101:1995+A1:2005 and EN 13772:2011, and has been carried out accelerated aging before testing according to ISO 3175-2:2010. The classification according to standard EN 13773:2003 is:

"CLASS 1"

Date of Issue

22st of September 2023

Date: 22/09/2023 13:29:49

Digitally Signed by:GEMA ESTEVE SILVESTRE -

NIF:21666152Z

Celia Dolça  
Head of Fire Behaviour lab.